



WARNING
 ENVIRONMENTAL ISSUES IN PLOT AREA
 EHV CABLES & LINES IN PLOT AREA
 MAJOR PIPELINE WITHIN 50M VICINITY CONTACT WWW.LINESEARCH.ORG
 OR PIPELINE OPERATOR. (OTHERS MAY EXIST)

33kV Point of Connection

NORMAL DEPTH TO THE TOP OF THE CABLE WHEN LAID

	services	l.v.	h.v.	e.h.v.
FOOTPATH	0.40m	0.45m	0.60m	0.75m
ROAD CROSSING	0.60m	0.60m	0.75m	0.90m
l.v./services	- up to 1000V.			
h.v.	- over 1000V. to 11,000V.			
e.h.v.	- 22,000V. to 132,000V.			

WARNING

There may have been subsequent alterations to the surface levels. Trial holes should be taken to determine positions and depth of cables. HS (G) 47 Booklet from the Health and Safety Executive - Avoiding Danger from Buried Cables - should be consulted before commencing excavation work. (available from HMSO)

WHEN WORKING IN THE VICINITY OF OVERHEAD LINES THE HEALTH AND SAFETY GUIDANCE NOTE G56 SHOULD BE CONSULTED. (AVAILABLE FROM HMSO)

BASED UPON THE ORDNANCE SURVEY MAP WITH THE SANCTION OF THE CONTROLLER OF H.M. STATIONERY OFFICE. CROWN COPYRIGHT RESERVED.

This copy has been made by us with the authority of SOUTHERN ELECTRIC plc pursuant to section 47 of the Copyright, Designs and Patents Act 1988 (the Act). Unless the Act provides a relevant exception to copyright, the copy must not be copied without the prior permission of the copyright owner.
 Target: SAS H55MA COL A3.ppt

Scottish and Southern Energy plc
 Registered in Scotland No 117119.
 Registered Office: Inverleith House
 206 Dundee Road,
 Perth. PH1 3AQ.

UNCONTROLLED COPY
 Subject to Revision Master held at

Scottish and Southern Energy

H.V. MAINS RECORD

MELKSHAM
 01225-701500

Grid Ref: SU04478838
 Scale: 1:10000
 Date: 31/07/2013